



Poly Vision Pte Ltd  
16 Tuas View Place,  
Singapore 637862  
**T** (65) 6569 0566  
**F** (65) 6569 3603  
**www.pv.com.sg**



AN ASME-LIANHE ZAOBAO AWARD

新加坡金字品牌奖

Singapore  
Prestige

Brand Award 13

Winner, SPBA - Established Brands



# HIRO STONE

SUSTAINABLE SURFACES





Poly Vision Pte Ltd  
 16 Tuas View Place,  
 Singapore 637862  
**T** (65) 6569 0566  
**F** (65) 6569 3603  
**www.pv.com.sg**



AN ASME-LIANHE ZAOBAO AWARD  
 新加坡金字品牌奖  
 Singapore  
 Prestige  
 Brand Award 13

Winner, SPBA - Established Brands

Remarks:			
For Stain Test, " * " denotes that noticeable mark was observed but the stain was able to be removed by dry			
or wet tissue paper. "***" denotes that the stain was easily removed by a light application of a mild abrasive.			
11	Colour Fading Test (Gloss 60°)	ASTM D2244 : 2016	
		ASTM D523 : 2014	
	a. Specimen 1 (Before/After Exposure)		49 / 45
	a. Specimen 2 (Before/After Exposure)		45 / 42
12	Cigarette Test	ANSI Z 124.6	No ignition or progressive glow of the surface during or after contact with the lighted cigarettes
	a. Stuyvesant		
	b. Camel		
	c. Winston		
13	Chemical Resistance Test	BS EN 14617-10 :2005	Passed
	a. Hydrochloric Acid		Class C4
	b. Sodium Hydroxide		Class C4
14	Antimicrobial Activity Evaluation	ASTM E 2180-18	<i>Percent Reduction</i>
	a. Staphylococcus aureus (ATCC 6538)		More than 99.997
	b. Klebsiella pneumoniae (ATCC 4352)		More than 99.998
15	Fire Propagation	BS476 Part 6:1989	i <sup>1</sup> = 0.0
			i <sup>2</sup> = 2.7
			i <sup>3</sup> = 2.0
			Index Overall Performance= 4.7
16	Surface Spread of Flame	BS476 Part 7:1989	Class 1